

DECLARATION OF CONFORMITY

Date: September 5, 2016

To Whom It May Concern

Honeywell Technologies SARL hereby declares:

The Honeywell C7061F1003 self-checking flame scanner is produced by:

I.D.R.M.
Z.I. du Sauvoy
25 avenue de Montboulon
77165 SAINT-SOUPPLETS
FRANCE

While respecting the general rules of the European standard EN 60079-0 and 61241-0, as well as the ATEX Directive 2014/34/EU.

Information Sheet INERIS 2015/01 declares that all existing ATEX certificates referring to C7061F1003 issued under the Directive 94/9/EC remain valid.

The C7061F1003 flame scanner components are built inside the IDRM model AD43200(0)1 enclosure meeting Ex d IIC T6 for Zone 1&2 for gas,
The I.D.R.M. AD43200(0)1 enclosure is ATEX certified by Ineris France under reference:

INERIS 03ATEX0158X

The ADL cable glands meeting Ex II 2 DG and Ex I M2 for Zone 1 & 2 for gas are made and produced by: Cooper Capri S.A.S
35 Rue des Fontenils
41600 NOUAN-LE-FUZELIER
FRANCE

The Capri ADE series cable glands are ATEX certified by INERIS under reference:

INERIS 12ATEX0032X


Honeywell Technologies Sarl
ACS - ECC EMEA
For and on behalf of Honeywell Technologies SARL.
Z.A. La Pièce 16
CH - 1180 Rolle
Switzerland

Honeywell Technologies SARL
Z.A. La Pièce 16
Rolle
CH-1180
Switzerland