



Number	18GR0308/01	Contract number	E8936
Issue date	04-06-2018	Scope	(EU) 2016/426 (9 March 2016)
Due date	04-06-2028	Module	B (Type testing)
PIN	0063AR1571	Report number	124961

EU TYPE EXAMINATION CERTIFICATE (GAR)

Kiwa hereby declares that the Pressure sensing device, type(s):

C6097 A2

manufactured by

**Honeywell Product and Solutions Sarl
Rolle, Switzerland**

meet(s) the essential requirements as described in the
Regulation (EU) 2016/426 relating to appliances burning gaseous fuels.

The compliance is based on examination to EN 1854:2010.

The product(s) has/have been approved for all EU and EFTA countries.

A description of the specific types is given in the appendix to this certificate.

Luc Leroy, Kiwa



Number	18GR0308/01	Page	1 of 1
Issue date	04-06-2018	Scope	(EU) 2016/426 (9 March 2016)
Due date	04-06-2028	Module	B (Type testing)
PIN	0063AR1571	Report number	124961

APPENDIX TO EU TYPE EXAMINATION CERTIFICATE (GAR)

C6097A2

Pressure sensing device approved on EN1854: 2010

Mounting positions: vertical and horizontal

Max. ambient temperature: -15°C - +60°

Max. fluid temperature: -15°C - +60°

Pmax: 200, 300, 500, or 600mbar

Degree of protection: IP54

Micro switch: 250V AC, 50 Hz 3A cos F = 0.6

250V AC, 50 Hz 5A resistive

Sensed medium: air, combustion products and combustible gas

Adjustable ranges:

- 1-10mbar $\pm 15\%$ full scale, pressure differential 0.4 mbar
- 2,5-50 mbar $\pm 15\%$ full scale, pressure differential 0.6 mbar
- 30-150 mbar $\pm 15\%$ full scale, pressure differential 2.8 mbar
- 100-500 mbar $\pm 15\%$ full scale, pressure differential 7 mbar