



Certificate of Compliance

Certificate: 70007864

Master Contract: 161061

Project: 70007864

Date Issued: September 9, 2014

Issued to: Maxon - A Honeywell Company

201 E 18th St
Muncie, IN 47302
USA
Attention: Peter Walthers

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only.



James Cotton

Issued by: James Cotton

PRODUCTS

CLASS 2258 82 - PROCESS CONTROL EQUIPMENT - For Hazardous Locations -
Certified to US Standards

CLASS 2258 02 - PROCESS CONTROL EQUIPMENT - For Hazardous Locations

Class I, Division 2, Groups A, B, C, D; T4A

- Model series S70x and S70xPF Flame Monitoring Viewing Head; Models: S702, S702PF, S706, S706PF; Electrical Rating: 22 to 26 Vdc, 150 mA max; Ambient Temperature: -40 °C to +85 °C; Enclosure Rating: IP64
- Model series S80x Flame Monitoring Viewing Head; Models: S802, S806; Electrical Rating: 22 to 26 Vdc, 150 mA max, 3.6 W max; Ambient Temperature: -40 °C to +85 °C; Enclosure Rating: IP64

Notes:

1. Model series S70xPF may include the suffix -050 or -200, designating the 50 ft (15.3 m) or 200 ft (61.0 m) long cable tail respectively. Either suffix may be included or excluded without affecting certification status.



Certificate: 70007864

Master Contract: 161061

Project: 70007864

Date Issued: September 9, 2014

APPLICABLE REQUIREMENTS

| | |
|--|---|
| CSA Std. C22.2 No. 0-10 | General Requirements – Canadian Electrical Code, Part II |
| C22.2 No. 142-M1987 (R 2009) | Process Control Equipment |
| C22.2 No. 213-M1987 (R 2013) | Non-Incendive electrical Equipment for use in Class I, Division 2 Hazardous Locations |
| CSA Std. C22.2 No. 60529:05 (R 2010) | Degrees of protection provided by enclosures (IP Code) |
| UL 508, Ed 17 (1999), including revisions through October 16, 2013 | Electrical Equipment for Industrial Control Equipment |
| ANSI/ISA 12.12.01-2013 | Nonincendive Electrical Equipment for Use in Class I and II, Division 2 and Class III, Divisions 1 and 2 Hazardous (Classified) Locations |
| ANSI/IEC 60529-2004 | Degrees of Protection Provided By Enclosures (IP Code) |

The following standard(s) were used in whole or in part as a guideline

| | |
|----------------------------|---|
| CSA Std. C22.2 No. 199-M89 | Combustion Safety Controls and Solid-State Igniters for Gas and Oil Burning Equipment |
| UL Std. 372 | Primary Safety Controls for Gas- and Oil-Fired Appliances |

MARKINGS

See Descriptive Report