


No. 2012-BO-0613



Safety Certificate

ILSHIN INDUSTRIAL ELECTRIC CO., LTD

26, 349 beon-gil, Jungang-gil, Kwangju-City, Gyeonggi-do, Republic of Korea

The following product produced by the above company has been authorized for the use of  the Mark as the product has satisfied the safety and health standards stipulated in the article 34 of mm Industrial Safety and Health Law.

PRODUCT

Flame Detector

TYPE · MODEL/CAPACITY · GRADE/CERTIFICATION No

TYPE · MODEL	CERTIFICATION No.
C7061F1011/C1011	12-AV2B0-0613
CAPACITY · GRADE	Ex d IIC T6 IP65
	AC 110 ~ 220 V, 50/60 Hz -20 °C ≤Ta≤+70 °C

SAFETY CERTIFICATION STANDARDS

Notification No. 2010-36 of the Ministry of Employment and Labor

CERTIFICATION CONDITION

It is only for the product manufactured in 26, 349 beon-gil, Jungang-gil, Kwangju-City, Gyeonggi-do, Republic of Korea

DATE : APR. 09. 2014

AUG. 31. 2012(Original issue)

Signature H. K. Baek

President of Korea Occupational Safety and Health Agency